

From: FSettepani@Geosyntec.com
Sent: Wednesday, July 28, 2010 7:12 AM
To: benh@goodfellowbros.com; douglasr@goodfellowbros.com; matth@goodfellowbros.com
Cc: Von Pein, Rick <rvonpein@wm.com>; Frey, Jesse <JFrey@wm.com>; HSharma@Geosyntec.com; APadovani@Geosyntec.com; Ron.Boyle@aecom.com; lsansone@geiconsultants.com; Dan.Frerich@aecom.com
Subject: Waimanalo: Response to RFI 041
Attach: Response to RFI 041 (28Jul10).pdf

Good morning Ben/Matt/Doug.

The response to RFI No. 41 is attached.

Geosyntec recommends that AECOM increase the gradation testing frequency listed on Table3-2 of the CQA Manual for the project to 1 sieve test every 750 cubic yards to verify that the fines content remains within specification.

Fabrizio.